



Electrosoft All in One Summary

Electrosoft by Acksen Ltd
www.electrocorder.com
v5.1.0 Build 0161

Name:	Smit Industrial	Reference No:		Model No:	EC664-VA-1K - 50Hz, 60024
Address:	Portadown Co. Armagh Northern Ireland United Kingdom	Logger Setup Date:	5/31/2006 3:50:54 PM	Unit ID:	XRGC4865E60024325A5D
Phone:		Averaging Start Date:	6/2/2006 11:10:29 AM	Recording Method:	Averaging Period 2 Minutes
		Averaging Stop Date:	6/12/2006 12:24:29 PM	No. Channels:	6
		Displayed Voltage:	Phase to Neutral		
		Current Range:	0-1000A		
		Filename:	C:\Documents and Settings\Bruce Lonie.BRUCES51\My Documents\Electrosoft\Electrocorder		



% of readings within +10% to -10% of Nominal: 7.9%

Notes:

Current Statistics:

A1min:	68A 6/4/2006 at 1:50:29 PM	A2min:	66A 6/4/2006 at 10:00:29 AM	A3min:	74A 6/10/2006 at 2:08:29 AM
A1avg:	243.7A	A2avg:	228.5A	A3avg:	251.0A
A1max:	604A 6/5/2006 at 12:12:29 PM	A2max:	562A 6/5/2006 at 12:12:29 PM	A3max:	577A 6/5/2006 at 12:12:29 PM